



Product Service

Attestation of Compliance

No. E8N 10 12 72433 048

Holder of Certificate: **GD Midea Heating & Ventilating Equipment Co.,Ltd.**

Penglai Industry Road, Beijiao, Shunde
528311 Foshan, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Electric fan-coil units (Fan Coil Unit)**

Model(s): **MKA-600F, MKA-750F, MKA-850F, MKA-950F, MKA-1200F, MKA-1500F**

Description of Object:


Rated voltage:	220-240 V~
Rated frequency:	50 Hz
Rated power input:	
MKA-600F	170 W, 0,74 A
MKA-750F	188 W, 0,82 A
MKA-850F	198 W, 0,86 A
MKA-950F	205 W, 0,89 A
MKA-1200F	197 W, 1,0 A
MKA-1500F	234 W, 1,2 A
Protection class:	I

Tested according to:

EN 55014-1/A1:2009
EN 55014-2/A2:2008
EN 61000-3-2/A2:2009
EN 61000-3-3:2008

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 647101030501



Date, 2010-12-01 (Tony Liu)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.